

Approved Body No. 1121

Certificate of Constancy of Performance

1121-CPR-UK-AF7619

In compliance with Construction Products Regulation 2011 (retained EU law EUR 2011/305) as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020, this certificate applies to the Construction Product:

Briton 6100 999.XXX / Bricard 6100 999X / Cisa 1.07155.61.0.XX Door Coordinators (Size 3 to 5)

Intended use:- For use on fire rated double leaf doors.

Essential characteristics	Performance	Harmonised technical specification
	Mechanical Test Evidence : WIL 355825 Fire Evidence : WF No 358184 Iss 3 & WF391041 Iss 2	
Self closing		
5.1 Product Information and design	Pass	EN 1158:1997/A1:2002/AC:2006
5.2.1 General	Pass	
5.2.2 Overload performance	Pass	
5.2.3 Manipulation performance	Pass	
5.2.4 Resistance of Waiting	Pass	
5.2.6 Damage	Pass	
5.2.8 Fire/smoke door suitability	Pass	
Essential characteristics	Performance	Harmonised technical specification
Durability of Self Closing	(Grade 5) 500,000 test cycles	EN 1158:1997/A1:2002/AC:2006
5.2.5 Durability		
5.2.17.1 corrosion	(Grade 3) 96hrs	
5.2.17.2 corrosion	(Grade 3) 96hrs	
Dangerous Substances Annex ZA3	Pass: the materials in the door coordinator do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations	

Approved Body No. 1121

Certificate of constancy of performance

1121-CPR-UK-AF7619

Placed on the market under the name of

**Allegion (UK) Limited
35 Rocky Lane,
Aston,
Birmingham,
West Midlands,
B6 5RQ
United Kingdom**

and produced in the manufacturing plant

E014110-20

This is coded format and the information is held by the Approved Body

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 1158:1997/A1:2002

Under System 1 for the performance set out in this certificate are applied and that the Factory Production Control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **02/12/2023** and will remain valid as long as neither the designated standard, the Construction Product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Approved Product Certification Body.

UKCA certificate valid to: **01/12/2026**



0087



Paul Duggan
Certification Manager

**Warringtonfire Testing and Certification Limited
Suite 302, The Genesis Centre, Birchwood, Warrington, WA3 7BH, UK**