

Declaration of Performance
**UK CONSTRUCTION PRODUCTS
(AMENDMENT ETC) (EU EXIT)
REGULATIONS 2020**
No. 47458035

1. Unique identification code of the product-type:

Briton 372, 372M, 372OEM, 372.P, 372M.P, 372OEM.P
Accessories: - 376MDS, Briton 1413/LE & 1413/KE, 1413.LE, 1413.KE & 1413.BP, Briton 9260 Codelock, P816 &816 Rim Cylinder

2. Type, batch or serial number or any other element allowing identification of the construction product as required under Article 11(4) of the UK CPR:

Briton 372, 372M, 372OEM, 372.P, 372M.P, 372OEM.P

3. Intended use or uses of the construction product, in accordance with the applicable designated technical specification, as foreseen by the manufacturer:

**For use on fire and smoke compartmentation doors
Or**
Escape route doors, when fitted in accordance with the manufacturer's fitting instructions.

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required under Article 11(5):

**Allegion (UK) Limited
35 Rocky Lane
Aston
Birmingham
B6 5RQ**

5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):

N/A

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in UK CPR, Annex V:

System 1

7. In case of the declaration of performance concerning a construction product covered by a designated standard:

EN 179: 2008
**Notified testing laboratory No.1121 performed the type testing and issued test reports.
Certificate of Constancy of Performance - 1121-CPR-UK- ABB7573**

8. UK Technical Assessment:

N/A

9. Declared performance

Essential characteristics	Performance	Designated technical specification
Clause 4.2.1 Ability to release (for doors on escape routes)		
Release function	< 1 sec	EN 179:2008
Release operation	Pass	
Lever handle	N/A	
Push pad	Pass	
Double doorset	Pass	
Exposed edges and corners	> 0,5 mm	
Push pad installation	Z < 250 mm	
Lever handle installation	N/A	
Operating element projection	W< 100mm or 150mm	
Operating element face (Lever handle)	N/A	
Operating element face (Push pad)	≥ 1400mm ²	
Lever handle operating gap	N/A	
Push pad operating gap	Pass	


Test rod Push pad release operation Accessible gap Door free movement Top vertical bolt Keepers Keepers dimensions Door mass and dimensions	Pass Pass Pass Pass Pass Pass Pass Door mass ≤ 200 Kg, door height ≤ 2520 mm, door width ≤ 1320 mm	
Outside access device Release forces	Pass Type B < 150 N	
Security requirement	Grade 4	
Clause 4.2.1 Durability of ability to release against aging and degradation (for doors on escape routes)		
Corrosion resistance Temperature range Covers for vertical rods Lubrication Re-engagement force Durability Abuse resistance – Operating Element Abuse resistance – Vertical rod Final examination	Grade 3: 96 h Operating forces at -10 C° and + 60 C° < 50% in excess of the operating forces at +20 C° N/A Lubrication every 20 000 cycles < 50 N Grade 7: 200 000 cycles 500 N & 1000N 500N Type B < 150 N	
Clause 4.2.1 Self closing ability C (for fire/smoke doors on escape routes) Re-engagement force	< 50 N	
Clause 4.2.1 Durability of self closing ability C against aging and degradation (for fire/smoke doors on escape routes) Durability Re-engagement force	Grade 7: 200 000 cycles < 50 N	
Clause 4.2.1 Resistance to fire E (integrity) and I (insulation) (for fire doors on escape routes) Suitability of panic exit devices for use on fire resisting doorsets assemblies – Additional requirements	Grade B: Suitable for use on fire/smoke door assemblies_A single leaf steel door assembly fitted with this device passed a fire test against EN 1634-1 Pass	
Clause 4.1.25 Control of Dangerous substances	If a reference to dangerous substances is added in the table ZA.1, the following claim is suggested: Pass: the materials in the hinge do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations (1)	

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:

Chris Crampton
Controller - Unitary EMEIA, Finance and Accounting



Allegion (UK) Limited
35 Rocky Lane
Aston
Birmingham
B6 5RQ

30th August 2021