

Notified Body No. 2812

## Certificate of Constancy of Performance

**2812-CPR-AAA0011**

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product:

### “BRITON 376 (See ANNEX A) 377 (See ANNEX B) 378 (See ANNEX C) & 379 (See ANNEX D) Series” Panic Exit Devices

**Intended use: For use on single and double leaf doors on escape routes, including fire resisting door assemblies**

Essential Characteristics	Performance	Harmonised Technical Specification
<b>Mechanical Test Evidence :</b> WIL 539076 / WIL 539077 / WIL 539078 / WIL 539079 & WIL 541902 <b>Fire Test Evidence :</b> WF 127579 / WF 417359 / WF 417361 / WF 539511/R / WF 542544/R & WF 544056 AR Iss 1		
<b>Clause 4.2.1 Ability to release</b> (for doors on panic routes) Release function Panic exit device mounting Exposed edges and corners Double doorset Single doorset Bar installation Bar length Bar projection Bar end Operating bar face Test rod Door face gap Accessible gap Door free movement Top vertical bolt Covers for vertical rods Keepers Keepers dimensions Door mass and dimensions  Outside access device Release forces  Security requirement	< 1 sec Pass > 0,5 mm Pass Pass Z < 150 mm > 60% W < 100mm Pass > 18 mm Pass > 25 mm Pass Pass Pass – (Annex A&B) NPD Pass Pass – (See Annex A&B) Door mass ≤ 200Kg, door height ≤ 2500mm, door width ≤ 1300mm Door Height increased to 3350mm when fitted with 376ELTS/SE – Extra Long Shoot Bolts Pass < 80N with the door unloaded, and < 220N with the door loaded with 1 000N Grade 2	<b>EN 1125:2008</b>
<b>Clause 4.2.1 Durability of ability to release against aging and degradation</b> (for doors on panic routes) Corrosion resistance Temperature range  Covers for vertical rods Lubrication Re-engagement force Durability Abuse resistance –Horizontal bar Abuse resistance –Vertical rod Final examination	Grade 3 : 96 Hours Operating forces at -10 C° and + 60 C° < 50% in excess of the operating forces at +20 C°  NPD Lubrication every 20 000 cycles < 50 N Grade 7: 200 000 cycles 1 000N 500N - (Annex A&B) < 80N with the door unloaded, and < 220N with the door loaded with 1 000N	

Notified Body No. 2812

## Certificate of Constancy of Performance

**2812-CPR-AAA0011**

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product:

### “**BRITON 376** (See ANNEX A) **377** (See ANNEX B) **378** (See ANNEX C) & **379** (See ANNEX D) **Series**” Panic Exit Devices

Essential Characteristics	Performance	Harmonised Technical Specification
<b>Clause 4.2.1 Self closing ability C</b> (for fire/smoke doors on escape routes) Re-engagement force	< 50N	<b>EN 1125:2008</b>
<b>Clause 4.2.1 Durability of self closing ability C against aging and degradation</b> (for fire/smoke doors on escape routes) Durability Re-engagement force	Grade 7: 200 000 cycles < 50N	
<b>Clause 4.2.1 Resistance to fire E (integrity) and I (insulation)</b> (For use on fire doors) Suitability of panic exit devices for use on fire resisting doorsets assemblies –  Additional requirements	Grade B : Suitable for use on fire door assemblies.	
<b>Clause 4.1.25 Control of Dangerous substances</b>	If a reference to dangerous substances is added in the table ZA.1, the following claim is suggested: Pass: the materials in the Device do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations.	

Notified Body No. 2812

## Certificate of Constancy of Performance

**2812-CPR-AAA0011**

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product:

### “BRITON 376 (See ANNEX A) 377 (See ANNEX B) 378 (See ANNEX C) & 379 (See ANNEX D) Series” Panic Exit Devices

BRITON PRODUCT CODES	DESCRIPTION	SINGLE DOOR USE	DOUBLE DOOR USE
<b>ANNEX A – 2 Point Vertical Locking</b>			
376.SE	Push Bar Panic Exit With Vertical Bolts	√	√
376M.SE	Push Bar Panic Exit With Vertical Bolts For Use With Metal Doors	√	√
<b>ANNEX B – 2 Point Vertical Locking (Inactive Leaf) &amp; 1 Point latch locking (Active Leaf)</b>			
377.SE	Push Bar Panic Exit With Vertical Bolts For Double Rebated Doors	---	√
377M.SE	Push Bar Panic Exit With Vertical Bolts For Double Rebated Metal Doors	---	√
<b>ANNEX C – 1 Point Rim Latch Locking</b>			
378.SE	Push Bar Rim Panic Latch	√	√
378M.SE	Push Bar Rim Panic Latch With Metal Strike& Fixings	√	√
<b>ANNEX D – 1 Point Mortice Rim Latch Locking</b>			
379.N.SE	Push Bar With Mortice Panic Nightlatch (Cylinder Not Included)	√	√
379M.N.SE	Push Bar With Mortice Nightlatch For Use With Metal Doors (Cylinder Not Included)	√	√
<b>COMPATIBLE OUTSIDE ACCESS DEVICES</b>			
1413.KE.SE	Outside Access Device With Knob For Use With Briton 372, 376, 377 & 378 Series	√	√
1413.LE.SE	Outside Access Device With Lever For Use With Briton 372, 376, 377 & 378 Series	√	√
1413.LE.SE.RO	ROBUST - Outside Access Device With Knob For Use With Briton 372, 376, 377 & 378 Series	√	√
1413.KE.SE.RO	ROBUST - Outside Access Device With Lever For Use With Briton 372, 376, 377 & 378 Series	√	√
<b>ACCESSORIES</b>			
376/1021/SE	Dogging End Box	√	√
380/1011/SE	Alarm End Box	√	√
376/1001/SE	Main Box Assembly	√	√
376/1011/SE	End Box Assembly	√	√
378/1001/SE	Latch Box Assembly	√	√
370PLTM	370 Series Panic Bolt Pullman fixing kit (376/372) Timber/Metal x2 pullmans plus instruction plus strikes/screws	√	√
376/413/SE	Crossbar - New Oval type	√	√
376/416/50	End Plug	√	√
376/931/SE	Pullman Assembly x 1 for replacement	√	√
379/931/SS	Night latch lock case	√	√
379/1001/SE	Mortice latch Box Assembly	√	√
378DDS/SE	377 Double Door Strike Timber	---	√
378MDS/SE	377 Double Door Strike Metal	---	√
376MDS/ZP	376 Metal Door Strike	√	√
379MDS/SE	379 Metal Door Strike	√	√
376ELTS/SE	Extra Long Shoot Bolts (For doors upto 3350mm)	√	√
376FFKP/ZP	Flush Face Keeper Plate	√	√

Notified Body No. 2812

## Certificate of Constancy of Performance

**2812-CPR-AAA0011**

Placed on the market under the Name of:

**Allegion (UK) Ltd  
35 Rocky Lane  
Birmingham  
West Midlands  
B6 5RQ  
United Kingdom**

and produced in the manufacturing plant:

**E014110-19**

**This is coded format, and the information is held by the Approved Body.**

This certificate attests that all provisions concerning the Assessment and Verification of Constancy of Performance described in Annex ZA of the standard(s):

**EN 1125:2008**

Under System 1 for the performance set out in this certificate are applied and that the Factory Production Control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **22/03/2021** and re-issued on **05/02/2025** and will remain valid as long as neither the harmonised standard, the Construction Product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Notified Product Certification Body.

Valid to: **02/04/2026**

ERO Project Reference: **ERO 034621 P2084**



**Pascal Coget  
General Manager - European Certification**

CSF408-NL 8.0