

Notified Body No. 2812

Certificate of Constancy of Performance

2812-CPR-AG0007

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

Briton 5240.57 Mortice Latch See Annex A

Intended use: For use on fire/smoke compartmentation doors

| Essential characteristics | Performance | Harmonised technical specification |
|--|--|------------------------------------|
| Mechanical test evidence: WIL 423759-1 Fire test evidence: WF 417361, WF 417363 & WF 428002 iss.1 | | |
| Self-closing 5.4.2 Closing force | Grade 8 = 200Kg door mass with 15N maximum closing force. | EN 12209:2003 / AC:2005 |
| 5.1.2 Re-latching force of latch bolt | >2.5N | |
| Durability of self-closing 5.3.1 Durability of latch action | Grade X = 200,000 cycles with 120N side load on latch bolt. | |
| Ability to maintain the door in the closed position and not contribute to its spread of fire | Grade 1: suitable for use on fire/smoke resistant door assemblies | |
| Dangerous substances | Pass: the materials in the lock do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations (1) | |

Certificate of Constancy of Performance

2812-CPR-AG0007

Placed on the market under the name of:

**Allegion (UK) Ltd
35 Rocky Lane, Aston,
Birmingham, B6 5RQ, United Kingdom**

and produced in the manufacturing plant

J/137

This is coded format and the information is held by the Notified Body

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard:

EN 12209:2003 / AC:2005

Under System 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **30/10/2020** and re-issued on **09/03/2023** and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Notified Product Certification Body.

CE Marking certificate valid to: **08/03/2026**

ERO Project Reference: **ERO 034621 P 1748**




Paul Duggan
Certification Manager

Certificate of Constancy of Performance

2812-CPR-AG0007

Annex A

| Model No. | Description | Backset | Centres |
|-----------|--------------------------------|---------|---------|
| 5240.57 | Mortice latch Square forend | 57mm | n/a |



CSF408-NL 7.0