

Approved Body No. 1121

## Certificate of Constancy of Performance

**1121-CPR-UK- AE7617**

In compliance with Construction Products Regulation 2011 (retained EU law EUR 2011/305) as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020, this certificate applies to the Construction Product:

### Briton 503 Electrically powered hold open Wall magnet (Size 3 to 6)

**Intended use:-** For use on fire rated single leaf and double leaf doors

**WALL MOUNT APPLICATION**

Essential characteristics	Performance	Designated Standard
<b>Mechanical Test Ref's : 108 PCT / 143578 &amp; WIL 519641</b> Fire Test Ref's : WF 142517 Iss 2 & WF 529491		
Ability to release 5.1.2 release from any angle 5.1.3 Not possible to inhibit the release 5.1.4 Supply voltage 5.1.5 External electrical connection 5.1.6 Inlet for external wiring  5.2.1 General 5.2.2 Electrical release requirements 5.2.3 Door closing device requirements  5.2.4 Durability 5.2.5 Angle of hold open 5.2.6 Manual release 5.2.7 Continuous hold open 5.2.8 Overload performance 5.2.9 Delayed release 5.2.10 Electrical performance 5.2.11 Temperature Rise 5.2.12 Damage 5.2.13 Fire / smoke doors	Pass Pass 24V Pass Pass  Pass Pass NPD  Pass Pass > 65° Pass Pass Pass NPD Pass Pass Grade 1	<b>EN1155:1997+A1:2002/AC:2006</b>
Essential characteristics	Performance	Designated Standard
Durability of Ability to release 5.2.4 Durability	50,000 Test Cycles	<b>EN1155:1997+A1:2002/AC:2006</b>
5.2.14.1 corrosion	Grade 3 (96 hours)	
5.2.14.2 corrosion	Pass	
Dangerous Substances Annex ZA3	Pass: the materials in the device do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations	

Approved body No. 1121

## Certificate of Constancy of Performance

**1121-CPR-UK- AE7617**

Placed on the market under the name of

**Allegion (UK) Ltd  
35 Rocky Lane  
Birmingham  
West Midlands  
B6 5RQ  
United Kingdom**

and produced in the manufacturing plant:

**E000709-3**

**This is coded format and the information is held by the Approved Body**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

**EN 1155:1997+A1:2002/AC:2006**

Under System 1 for the performance set out in this certificate are applied and that the Factory Production Control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **15/07/2021** and re-issued on **08/02/2024** and will remain valid as long as neither the harmonised standard, the Construction Product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Approved Product Certification Body.

UKCA certificate valid to: **14/07/2027**



0087



Paul Duggan  
Certification Manager

**Warringtonfire Testing and Certification Limited  
Suite 302, The Genesis Centre, Birchwood, Warrington, WA3 7BH, UK**