

Approved Body No. 1121

Certificate of Constancy of Performance

1121-CPR-UK-AG7921

In compliance with Construction Products Regulation 2011 (retained EU law EUR 2011/305) as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020, this certificate applies to the Construction Product:

Allegion 5700 Series Mortice Sashlock, Bathroom Lock, Latch, Night Latch & Escape Lock See Annex A

Intended use: For use on fire/smoke compartmentation doors

Essential characteristics	Performance	Designated standard
Mechanical test evidence: WIL 505264, WIL 505872, WIL 505872-2, WIL 505611 & WIL 512043 Fire test evidence: WF 413358 iss.2 & WF 422917 iss 3		
Self-closing ability 5.4.2 Closing force	Grade 8: 200Kg door mass with 15N maximum closing force.	EN 12209:2003 / AC:2005
5.1.2 Return force of latch bolt	>2.5N	
Durability of self-closing action 5.3.1 Durability of latch action	Grade X: 200,000 cycles with 120N side load on latch bolt.	
Ability to maintain the door in the closed position and not contribute to its spread of fire 5.2.1 Resistance to side load on latch bolt	Grade 3: 3kN	
5.5 Suitability for use on fire/smoke doors	Grade 1: suitable for use on fire/smoke resistant door assemblies	
Control of dangerous substances 5.1.1 Dangerous substances	Pass: The materials in the lock do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations (1)	

Approved Body No. 1121

Certificate of Constancy of Performance

1121-CPR-UK-AG7921

Placed on the market under the name of:

**Allegion (UK) Ltd
35 Rocky Lane
Aston
Birmingham
West Midlands
B6 5RQ
United Kingdom**

and produced in the manufacturing plant:

E014110-13

This is coded format, and the information is held by the Approved Body.

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard:

EN 12209:2003 / AC:2005

Under System 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the Construction Product.

This certificate was first issued on **04/07/2022** and reissued on **22/08/2025** and will remain valid as long as neither the designated standard, the Construction Product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Approved Product Certification Body.

UKCA certificate valid to: **03/07/2028**



0087

A handwritten signature in black ink, appearing to read 'Paul Duggan'.

**Paul Duggan
Certification Manager**

**Warringtonfire Testing and Certification Limited
Unit 722 The Quadrant, Birchwood Park, Warrington, Cheshire, WA3 6FW**

Approved Body No. 1121

Certificate of Constancy of Performance

1121-CPR-UK-AG7921

Annex A

Model No.	Description	Backset	Centres
5720.60.S.SS 5720.60.R.SS	Mortice euro profile sash lock Square or radiused forend	60mm	72mm
5730.60.S.SS 5730.60.R.SS	Mortice bathroom lock Square or radiused forend	60mm	78mm
5740.60.S.SS 5740.60.R.SS	Mortice latch Square or radiused forend	60mm	n/a
5750.60.S.SS 5750.60.R.SS	Mortice euro profile night latch Square or radiused forend	60mm	72mm
5760.60.S.SS 5760.60.R.SS	Mortice euro profile escape lock Square or radiused forend	60mm	72mm

Forends available in the following finishes:

SS Satin stainless steel