

Approved Body No. 1121

Certificate of Constancy of Performance

1121-CPR-UK-AE7615

In compliance with Construction Products Regulation 2011 (retained EU law EUR 2011/305) as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020, this certificate applies to the Construction Product:

Briton 9963 Electrically powered hold open & Free swing door closer (Size 3)

**Intended use: For use on fire single leaf and double leaf doors
STANDARD DOOR MOUNT PULL, TRANSOM MOUNT PUSH & PARALLEL ARM FIXING APPLICATIONS.**

| Essential characteristics | Performance | Designated Standard |
|---|---|-----------------------------|
| Mechanical Test ref's : 141035 / 141035/P / 141717 & WIL 430220 | | |
| Fire Test Ref's : WF 148518 / WF 148519 / WF 417359 / WF 417360 Iss 3 & WF 422918 Iss 2 | | |
| Ability to release 5.1.2 release from any angle 5.1.3 Not possible to inhibit the release 5.1.4 Supply voltage 5.1.5 External electrical connection 5.1.6 Inlet for external wiring 5.2.1 General 5.2.2 Electrical release requirements 5.2.4 Durability 5.2.5 Angle of hold open 5.2.6 Manual release 5.2.7 Continuous hold open 5.2.8 Overload performance 5.2.9 Delayed release 5.2.10 Electrical performance 5.2.11 Temperature Rise 5.2.12 Damage 5.2.13 Fire / smoke doors | Pass Pass Pass Pass Pass Pass Pass Pass Pass Pass Pass Pass Pass Pass Pass Grade 1 | EN1155:1997+A1:2002/AC:2006 |
| Essential characteristics | Performance | Designated Standard |
| Durability of Ability to release 5.2.14.1 corrosion 5.2.14.2 corrosion | Grade 3 (96 hours) Pass | |
| Dangerous Substances Annex ZA3 | If a reference to dangerous substances is added in the table ZA.1, the following claim is suggested: Pass: the materials in this product do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations | EN1155:1997+A1:2002/AC:2006 |

Approved Body No. 1121

Certificate of Constancy of Performance

1121-CPR-UK-AE7615

Placed on the market under the name of:

**Allegion (UK) Ltd
35 Rocky Lane
Birmingham
West Midlands
B6 5RQ
United Kingdom**

and produced in the manufacturing plant:

E014110-20

This is coded format and the information is held by the Notified Body

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 1155:1997+A1:2002/AC:2006

Under System 1 for the performance set out in this certificate are applied and that the Factory Production Control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **15/07/2021** and reissued on **07/05/2026** and will remain valid as long as neither the designated standard, the Construction Product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Approved Product Certification Body.

UKCA certificate valid to: **10/09/2026**



0087



**Paul Duggan
Certification Manager**

**Warringtonfire Testing and Certification Limited
Unit 722 The Quadrant, Birchwood Park, Warrington, Cheshire, WA3 6FW**