

Approved Body No. 1121

Certificate of Constancy of Performance

1121-CPR-UK-AE7616

In compliance with Construction Products Regulation 2011 (retained EU law EUR 2011/305) as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020, this certificate applies to the Construction Product:

Briton 9964 Electrically Powered Hold Open & Free Swing Door Closer (Size 4)

Intended use:- For use on fire rated single leaf and double leaf doors

STANDARD DOOR MOUNT PULL, TRANSOM MOUNT PUSH & PARALLEL ARM FIXING APPLICATIONS

Essential characteristics	Performance	Designated Standard
Test Mechanical Ref : 141107 / 141107/P / 142849 & 142849/F Fire Test Evidence : WF 148518 / WF 148519 / WF 417359 / WF 417360 Iss 3 & WF 422918 Iss 2		
Ability to release 5.1.2 release from any angle 5.1.3 Not possible to inhibit the release 5.1.4 Supply voltage 5.1.5 External electrical connection 5.1.6 Inlet for external wiring 5.2.1 General 5.2.2 Electrical release requirements 5.2.4 Durability 5.2.5 Angle of hold open 5.2.6 Manual release 5.2.7 Continuous hold open 5.2.8 Overload performance 5.2.9 Delayed release 5.2.10 Electrical performance 5.1.11 Temperature Rise 5.1.12 Damage 5.1.13 Fire / smoke doors	Pass Pass Pass Pass Pass Pass Pass Pass Pass Pass Pass Pass Pass Pass Pass Grade 1	EN 1155:1997+A1:2002/AC:2006
Essential characteristics	Performance	Designated Standard
Durability of Ability to release 5.2.14.1 corrosion 5.2.14.2 corrosion	Grade 3 (96 hours) Pass	EN 1155:1997+A1:2002/AC:2006
Dangerous Substances Annex ZA3	If a reference to dangerous substances is added in the table ZA.1, the following claim is suggested: Pass: the materials in the product do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations	

Approved Body No. 1121

Certificate of Constancy of Performance

1121-CPR-UK-AE7616

Placed on the market under the name of:

**Allegion Safety & Security Solutions Limited
Orbital 60
Dumers Lane
Bury
BL9 9UE
United Kingdom**

and produced in the manufacturing plant:

E018761-16

This is coded format, and the information is held by the Notified Body.

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 1155:1997+A1:2002/AC:2006

Under System 1 for the performance set out in this certificate are applied and that the Factory Production Control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **15/07/2021** and revised on **18/06/2026** and will remain valid as long as neither the designated standard, the Construction Product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Approved Product Certification Body.

UKCA certificate valid to: **10/09/2026**



0087

Paul Duggan
Certification Manager

**Warringtonfire Testing and Certification Limited
Unit 722 The Quadrant, Birchwood Park, Warrington, Cheshire, WA3 6FW**