warringtonfire
Proud to be part of element

Approved Body No. 1121

Certificate of Constancy of Performance

1121-CPR-UK-AE7608

In compliance with Construction Products Regulation 2011 (retained EU law EUR 2011/305) as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020, this certificate applies to the Construction Product:

Briton 9965/01/SES & 9965/66/SES Electrically powered hold open & Free swing door closer (Size 5)

Intended use: For use on fire single leaf and double leaf doors
STANDARD DOOR MOUNT PULL & PARALLEL ARM FIXING APPLICATIONS.

Essential characteristics	Performance	Designated Standard
Mechanical Test ref's : WIL 558302 Iss 2 / WIL 558305 & WIL 560315 Iss 1 **Fire Test Ref's :** WF 417359 / WF 422918 Iss 4 & WF 558734/R		
Ability to release		EN1155:1997+A1:2002/AC:2006
5.1.2 release from any angle	Pass	
5.1.3 Not possible to inhibit the release	Pass	
5.1.4 Supply voltage	Pass	
5.1.5 External electrical connection	Pass	
5.1.6 Inlet for external wiring	Pass	
5.2.1 General	Pass	
5.2.2 Electrical release requirements	Pass	
5.2.4 Durability	Pass	
5.2.5 Angle of hold open	Pass	
5.2.6 Manual release	Pass	
5.2.7 Continuous hold open	Pass	
5.2.8 Overload performance	Pass	
5.2.9 Delayed release	NPD	
5.2.10 Electrical performance	Pass	
5.2.11 Temperature Rise	Pass	
5.2.12 Damage	Pass	
5.2.13 Fire / smoke doors	Grade 1	
Essential characteristics	**Performance**	**Designated Standard**
Durability of Ability to release		EN1155:1997+A1:2002/AC:2006
5.2.14.1 corrosion	Grade 3 (96 hours)	
5.2.14.2 corrosion	Pass	
Dangerous Substances Annex ZA3	If a reference to dangerous substances is added in the table ZA.1, the following claim is suggested: Pass: the materials in the product do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations	

This certificate is the property of Warringtonfire Testing and Certification Limited. Registered in England and Wales
Registered Office: 3rd Floor, Davidson Building, 5 Southampton Street, London, WC2E 7HA. Company Registration No: 11371436

warringtonfire
Proud to be part of element

Approved Body No. 1121

Certificate of Constancy of Performance

1121-CPR-UK-AE7608

Placed on the market under the name of:

ALLEGION SAFETY & SECURITY SOLUTIONS LIMITED
ORBITAL 60
DUMERS LANE
BURY
BL9 9UE
UNITED KINGDOM

and produced in the manufacturing plant:

E018761-9

This is coded format, and the information is held by the Notified Body.

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 1155:1997+A1:2002/AC:2006

Under System 1 for the performance set out in this certificate are applied and that the Factory Production Control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **15/07/2021** and reissued on **11/11/2026** and will remain valid as long as neither the designated standard, the Construction Product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Approved Product Certification Body.

UKCA certificate valid to: **14/07/2029**

UKAS PRODUCT CERTIFICATION
0087

Paul Duggan
Certification Manager

Warringtonfire Testing and Certification Limited
Unit 722 The Quadrant, Birchwood Park, Warrington, Cheshire, WA3 6FW

This certificate is the property of Warringtonfire Testing and Certification Limited. Registered in England and Wales
Registered Office: 3rd Floor, Davidson Building, 5 Southampton Street, London, WC2E 7HA. Company Registration No: 11371436