

Approved Body No. 1121

Certificate of Constancy of Performance
1121-CPR-UK-AG7626

In compliance with Construction Products Regulation 2011 (retained EU law EUR 2011/305) as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020, this certificate applies to the Construction Product:

Briton 5400 & AXA 7000 Series Locks
See Annex A

Intended use: For use on fire/smoke compartmentation doors

Essential characteristics	Performance	Designated standard
Mechanical test evidence: WIL 414122, WIL 414123 & WIL 414786 Fire test evidence: WF 417357 & WF 422917 iss.3		
Self-closing 5.4.2 Closing force	Grade 8 = 200Kg door mass with 15N maximum closing force.	EN 12209:2003 / AC:2005
5.1.2 Re-latching force of latch bolt	>2.5N	
Durability of self-closing 5.3.1 Durability of latch action	Grade X = 200,000 cycles with 120N side load on latch bolt.	
Ability to maintain the door in the closed position and not contribute to its spread of fire	Grade 1: suitable for use on fire/smoke resistant door assemblies	
Dangerous substances	Pass: the materials in the lock do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations (1)	

Approved Body No. 1121

Certificate of Constancy of Performance
1121-CPR-UK-AG7626

Placed on the market under the name of

Allegion (UK) Ltd
35 Rocky Lane
Aston
Birmingham
B6 5RQ
United Kingdom

and produced in the manufacturing plant

E014110-15

This is coded format, and the information is held by the Approved Body

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 12209:2003 / AC:2005

Under System 1 for the performance set out in this certificate are applied and that the Factory Production Control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **15/07/2021** and reissued on **07/05/2026** will remain valid as long as neither the designated standard, the Construction Product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Approved Product Certification Body.

UKCA certificate valid to: **15/09/2026**



0087



Paul Duggan
Certification Manager

Warringtonfire Testing and Certification Limited
Unit 722, The Quadrant, Birchwood Park, Warrington, WA3 6FW, UK

Approved Body No. 1121

Certificate of Constancy of Performance

1121-CPR-UK-AG7626

Annex A

Model No.		Description	Backset
Briton 5420.60	AXA 7045	Mortice Sashlock	60mm
Briton 5430.60	AXA 7065	Bathroom Lock	60mm
Briton 5440.60	AXA 7055	Mortice Latch	60mm
Briton 5420.55		Mortice Sashlock	55mm
Briton 5430.55		Bathroom Lock	55mm
Briton 5440.55		Mortice Latch	55mm