

Notified Body No. 2812

## Certificate of Constancy of Performance

### 2812-CPR-AD5311

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

## Briton 131.XX, Bricard 61311XX, Cisa C1455.03.0.XX Overhead Door Closers

**Intended use: For use on fire rated single leaf and double leaf doors  
STANDARD FIXING POSITION**

Essential characteristics	Performance	Harmonised Technical Specification
<b>Mechanical Test Evidence: WIL 372432</b> <b>Fire Test Evidence: WF 375469</b>		
Self-closing		EN1154:1996/A1:2002/AC:2006
5.2.1 General		
5.2.2 Durability	500,000 test cycles	
5.2.3 Closing moment	Pass size 2 to 4	
5.2.4 Opening moment	Pass size 2 to 4	
5.2.5 Efficiency	> 50% size 2	
5.2.5 Efficiency	> 60% size 4	
5.2.6 Closing time	Pass	
5.2.7 Angles of operation	Grade 3 > 105°	
5.2.8 Overload performance	Pass	
5.2.9 Temp dependence	-15°C to +40°C	
5.2.10 Fluid leakage	Pass	
5.2.11 Damage	Pass	
5.2.12 Latch control	Pass	
5.2.13 Back check (optional)	NPD	
5.2.14 Delayed closing (optional)	NPD	
5.2.15 Adjustable closing force (optional)	Pass	
5.2.16 Zero position (double action door closers only)	NPD	
5.2.18 Fire/smoke door suitability	Pass	
Essential characteristics	Performance	Harmonised Technical Specification
Durability of Self Closing		EN1154:1996/A1:2002/AC:2006
5.2.2 Durability	500,000 test cycles	
5.2.17.1 Corrosion	Grade 3 (96 hours)	
5.2.17.2 Corrosion	Pass	
Dangerous Substances Annex ZA3	Pass: the materials in the door closer do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations	EN1154:1996/A1:2002/AC:2006

Notified Body No. 2812

## Certificate of Constancy of Performance

### 2812-CPR-AD5311

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

## Briton 131.XX, Bricard 61311XX, Cisa C1455.03.0.XX Overhead Door Closers

**Intended use: For use on fire rated single leaf and double leaf doors  
PARALLEL ARM APPLICATION**

Essential characteristics	Performance	Harmonised Technical Specification
Self-closing		EN1154:1996/A1:2002/AC:2006
5.2.1 General		
5.2.2 Durability	500,000 test cycles	
5.2.3 Closing moment	Pass size 3	
5.2.4 Opening moment	Pass size 3	
5.2.5 Efficiency	> 55% size 3	
5.2.6 Closing time	Pass	
5.2.7 Angles of operation	Grade 3 > 105°	
5.2.8 Overload performance	Pass	
5.2.9 Temp dependence	-15°C to +40°C	
5.2.10 Fluid leakage	Pass	
5.2.11 Damage	Pass	
5.2.12 Latch control	NPD	
5.2.13 Back check (optional)	NPD	
5.2.14 Delayed closing (optional)	NPD	
5.2.15 Adjustable closing force (optional)	NPD	
5.2.16 Zero position (double action door closers only)	NPD	
5.2.18 Fire/smoke door suitability	Pass	
Essential characteristics	Performance	Harmonised Technical Specification
Durability of Self Closing		EN1154:1996/A1:2002/AC:2006
5.2.2 Durability	500,000 test cycles	
5.2.17.1 Corrosion	Grade 3 (96 hours)	
5.2.17.2 Corrosion	Pass	
Dangerous Substances Annex ZA3	Pass: the materials in the door closer do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations	

Notified Body No. 2812

## Certificate of Constancy of Performance

### 2812-CPR-AD5311

Placed on the market under the name or trade mark of

**Allegion (UK) Limited**  
**35 Rocky Lane**  
**Aston**  
**Birmingham**  
**B6 5RQ, UK**  
**United Kingdom**

and produced in the manufacturing plant

**E14110-20**

**This is coded format and the information is held by the Notified Body**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard:

**EN 1154:1996 / A1:2002 / AC:2006**

Under System 1 for the performance set out in this certificate are applied and that the Factory Production Control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **05/11/2020** and re-issued **09/02/2024** and will remain valid as long as neither the harmonised standard, the Construction Product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Notified Product Certification Body.

CE Marking certificate valid to: **08/02/2027**

ERO Project Reference: **034621 P2101**



Pascal Coget  
General Manager - European

CSF408-NL 8.0