

Notified Body No. 2812

Certificate of Constancy of Performance

2812-CPR-AF5003

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

Briton 6100 999.XXX / Bricard 6100 999X / Cisa 1.07155.61.0.XX Door Coordinators (Size 3 to 5)

Intended use:- For use on fire rated double leaf doors.

Essential Characteristics	Performance	Harmonised Technical Specification
Mechanical Test Ref's : WIL 355825		
Fire Test Ref's : WF No 358184 Iss 3 & WF 391041 Iss 2		
Self closing		EN 1158:1997/A1:2002/AC:2006
5.1 Product Information and design	Pass	
5.2.1 General	Pass	
5.2.2 Overload performance	Pass	
5.2.3 Manipulation performance	Pass	
5.2.4 Resistance of Waiting	Pass	
5.2.6 Damage	Pass	
5.2.8 Fire/smoke door suitability	Pass	
Essential Characteristics	Performance	Harmonised Technical Specification
Durability of Self Closing	(Grade 5)	EN 1158:1997/A1:2002/AC:2006
5.2.5 Durability	500,000 test cycles	
5.2.7.1 corrosion	(Grade 3) Pass	
5.2.7.2 corrosion	(Grade 3) Pass	
Dangerous Substances Annex ZA3	Pass: the materials in the door coordinator do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations	

Notified Body No. 2812

Certificate of Constancy of Performance
2812-CPR-AF5003

Placed on the Market under the Name of:

Allegion (UK) Ltd
35 Rocky Lane
Aston
Birmingham
B6 5RQ
United Kingdom

and produced in the manufacturing plant

K/033

This is coded format and the information is held by the Notified Body.

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 1158:1997/A1:2002/AC:2006

Under System 1 for the performance set out in this certificate are applied and that the Factory Production Control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **30/10/2020** and revised on **10/06/2023** and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Notified Product Certification Body.

CE Marking certificate valid to: **29/01/2026**

ERO Project Reference: **ERO 034621 P1943**



Paul Duggan
Certification Manager

CSF408-NL 70