

Notified Body No. 2812

## Certificate of Constancy of Performance

### 2812-CPR-AG5190

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

### Briton 5400 Series Roller Latch See Annex A

Intended use: For use on fire/smoke compartmentation doors

Essential characteristics	Performance	Harmonised technical specification
Mechanical test evidence: WIL 414125 Fire test evidence: WF 417357 & WF 4229176 iss.3		
Self-closing 5.4.2 Closing force  5.1.2 Re-latching force of latch bolt	Grade 8 = 200Kg door mass with 15N maximum closing force.  >2.5N	EN 12209:2003 / AC:2005
Durability of self-closing 5.3.1 Durability of latch action	Grade C = 200,000 cycles with no side load on latch bolt.	
Ability to maintain the door in the closed position and not contribute to its spread of fire	Grade 1: suitable for use on fire/smoke resistant door assemblies	
Dangerous substances	Pass: the materials in the lock do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations (1)	

Notified Body No. 2812

## Certificate of Constancy of Performance

### 2812-CPR-AG5190

Placed on the market under the name of:

**Allegion (UK) Ltd  
35 Rocky Lane  
Aston  
Birmingham  
B6 5RQ  
United Kingdom**

and produced in the manufacturing plant

**J/311**

**This is coded format and the information is held by the Notified Body**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard:

**EN 12209:2003 / AC:2005**

Under System 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **05/11/2020** and re-issued on **06/09/2023** and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Notified Product Certification Body.

CE Marking certificate valid to: **05/09/2026**

ERO Project Reference: **ERO 034621 P2036**



Pascal Coget  
General Manager - European Certification

CSF408-NL 7.0

Notified Body No. 2812

## Certificate of Constancy of Performance

### 2812-CPR-AG5190

#### Annex A

Model No.	Description	Backset
Briton 5470.60	Roller Latch	60mm
Briton 5470.55	Roller Latch	55mm