

Notified Body No. 2812

Certificate of Constancy of Performance

2812-CPR-AG7925

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product:

Allegion 5700 Series Locks – See Annex A

Intended use: For use on fire/smoke compartmentation doors

Essential characteristics	Performance	Harmonised technical specification
	Mechanical & Fire test evidence: WIL 505264, WIL 505872, WIL 505872-1, WIL 505872-2, WIL 505611, WIL 512043 & WF 422917 Iss 3	
Self-closing 5.4.2 Closing force	Grade 8 = 200kg door mass with 15N maximum closing force	EN 12209:2003/AC 2005
5.1.2 Re-latching force of latch bolt	>2.5N	
Durability of self-closing 5.3.1 Durability of latch action	Grade X = 200,000 cycles with 120N side load on latch bolt.	
Ability to maintain the door in the closed position and not contribute to its spread of fire	Grade 1	
Control of Dangerous substances	If a reference to dangerous substances is added in the table ZA.1, the following claim is suggested: Pass: the materials in the lock do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations (1)	

Certificate of Constancy of Performance

2812-CPR-AG7925

Placed on the market under the name of

**Allegion (UK) Ltd
35 Rocky Lane
Aston, Birmingham
B6 5RQ**

and produced in the manufacturing plant

J/138

This certificate attests that all provisions concerning the Assessment and Verification of Constancy of Performance described in Annex ZA of the standard(s):

EN 12209:2003/AC 2005

Under System 1 for the performance set out in this certificate are applied and that the Factory Production Control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **09/08/2022** and will remain valid as long as neither the harmonised standard, the Construction Product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Notified Product Certification Body.

CE Marking certificate valid to: **08/08/2025**

ERO Project Reference: **ERO 034621 P1420**



Paul Duggan
Certification Manager

Certificate of Constancy of Performance

2812-CPR-AG7925

Annex A

Model reference	Product Description
5720	Mortice Euro Profile Sashlock
5730	Bathroom Lock
5740	Mortice Latch
5750	Mortice Nightlatch
5760	Escape Lock