

Certificate of Constancy of Performance

2812-CPR-AE0008

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product:

Briton 9964 Electrically powered hold open & Free swing door closer (Size 4)

Intended use: For use on fire single leaf and double leaf doors

STANDARD DOOR MOUNT PULL, TRANSOM MOUNT PUSH & PARALLEL ARM FIXING APPLICATIONS.

Essential characteristics	Performance	Harmonised technical specification
Mechanical Test Ref's : 141107 / 141107/P / 142849 & 142849/F		
Fire Test Ref's : WF 140181 / WF 148518 / WF 148519 / WF 417359 / WF 417360 Iss 3 & WF 422918 Iss 2		
Ability to release	Pass	
5.1.2 release from any angle	Pass	
5.1.3 Not possible to inhibit the release	Pass	
5.1.4 Supply voltage	Pass	
5.1.5 External electrical connection	Pass	
5.1.6 Inlet for external wiring	Pass	
5.2.1 General	Pass	
5.2.2 Electrical release requirements	Pass	
5.2.4 Durability	Pass	
5.2.5 Angle of hold open	Pass	
5.2.6 Manual release	Pass	
5.2.7 Continuous hold open	Pass	
5.2.8 Overload performance	Pass	
5.2.9 Delayed release	NPD	
5.2.10 Electrical performance	Pass	
5.2.11 Temperature Rise	Pass	
5.2.12 Damage	Pass	
5.2.13 Fire / smoke doors	Grade 1	
Essential characteristics	Performance	Harmonised technical specification
Durability of Ability to release	Grade 3 (96 hours) Pass	
Dangerous Substances Annex ZA3	If a reference to dangerous substances is added in the table ZA.1, the following claim is suggested: Pass: the materials in the hinge do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations	EN1155:1997+A1:2002/AC:2006



Notified Body No. 2812

Certificate of Constancy of Performance

2812-CPR-AE0008

Placed on the Market under the Name of:

**Allegion (UK) Ltd
35 Rocky Lane
Birmingham
West Midlands
B6 5RQ
United Kingdom**

and produced in the manufacturing plant:

V/017

This is coded format, and the information is held by the Notified Body.

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 1155:1997+A1:2002/AC:2006

Under System 1 for the performance set out in this certificate are applied and that the Factory Production Control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **29/10/2020** and reissued on **22/01/2026** and will remain valid as long as neither the harmonised standard, the Construction Product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Notified Product Certification Body.

CE Marking certificate valid to: **28/09/2026**

ERO Project Reference: **ERO 034621 P1746**

**Pascal Coget
European Certification –General Manager**

CSF408-NL 8.0

