

Notified Body No. 2812

## Certificate of Constancy of Performance

**2812-CPR-AE10495**

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product:

### **Allegion Briton 2420.T.EHO / Boss Door Controls ITS6.24SA-EMF & CISA 107209220 Concealed Electrically Powered Hold Open Door Closer (Size 3 to 4)**

**Intended use: For use on fire single leaf and double leaf doors  
CONCEALED IN DOOR APPLICATION**

Essential Characteristics	Performance	Harmonised Technical Specification
<b>Mechanical Test Ref's : WIL 405400 / WIL 422035 / WIL 427964 / WIL 427964-2 &amp; WIL 553430</b> <b>Fire Test Ref's :WF 153131 Iss 12 / WF 314208 Iss 2 / WF 324426 Iss 3 / WF 375219 Iss 2 / &amp; WF 385688 Iss 3</b>		
<b>Ability to release</b> 5.1.2 release from any angle 5.1.3 Not possible to inhibit the release 5.1.4 Supply voltage 5.1.5 External electrical connection 5.1.6 Inlet for external wiring  5.2.1 General 5.2.2 Electrical release requirements 5.2.3 Door closing device requirements (EN1154)  5.2.4 Durability 5.2.5 Angle of hold open 5.2.6 Manual release 5.2.7 Continuous hold open 5.2.8 Overload performance 5.2.9 Delayed release 5.2.10 Electrical performance 5.2.11 Temperature Rise 5.2.12 Damage 5.2.13 Fire / smoke doors	Pass Pass 24v Pass Pass  Pass Pass Pass  Pass >65° Pass Pass Pass NPD Pass Pass Pass Grade 1	<b>EN1155:1997+A1:2002/AC:2006</b>
<b>Essential Characteristics</b>  <b>Durability of Ability to release</b> 5.2.4 Durability 5.2.14.1 corrosion 5.2.14.2 corrosion  <b>Dangerous Substances Annex ZA3</b>	<b>Performance</b>  50,000 Test Cycles Grade 3 (96 Hours) Pass  Pass: the materials in the device do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations	
<b>Essential Characteristics</b>  <b>Durability of Ability to release</b> 5.2.4 Durability 5.2.14.1 corrosion 5.2.14.2 corrosion  <b>Dangerous Substances Annex ZA3</b>	<b>Performance</b>  50,000 Test Cycles Grade 3 (96 Hours) Pass  Pass: the materials in the device do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations	<b>Harmonised Technical Specification</b>  <b>EN1155:1997+A1:2002/AC:2006</b>

Notified Body No. 2812

## Certificate of Constancy of Performance

**2812-CPR-AE10495**

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product:

### Allegion Briton 2320B.T.EHO & 2321B.T.EHO Surface Mounted Electrically Powered Hold Open Door Closer (Size 3 to 4)

**Intended use: For use on fire single leaf and double leaf doors  
DOOR MOUNT PULL AND DOOR MOUNT PUSH SIDE APPLICATIONS**

Essential Characteristics	Performance	Harmonised Technical Specification
<p><b>Ability to release</b></p> <p>5.1.2 release from any angle 5.1.3 Not possible to inhibit the release 5.1.4 Supply voltage 5.1.5 External electrical connection 5.1.6 Inlet for external wiring</p> <p>5.2.1 General 5.2.2 Electrical release requirements 5.2.3 Door closing device requirements (EN1154)</p> <p>5.2.4 Durability 5.2.5 Angle of hold open 5.2.6 Manual release 5.2.7 Continuous hold open 5.2.8 Overload performance 5.2.9 Delayed release 5.2.10 Electrical performance 5.2.11 Temperature Rise 5.2.12 Damage 5.2.13 Fire / smoke doors</p>	<p>Pass Pass 24v Pass Pass</p> <p>Pass Pass Pass</p> <p>Pass &gt;65° Pass Pass Pass NPD Pass Pass Pass Grade 1</p>	<p><b>EN1155:1997+A1:2002/AC:2006</b></p>
<b>Essential Characteristics</b>	<b>Performance</b>	<b>Harmonised Technical Specification</b>
<b>Durability of Ability to release</b>		
5.2.4 Durability	50,000 Test Cycles	
5.2.14.1 corrosion	Grade 3 (96 Hours)	
5.2.14.2 corrosion	Pass	
<b>Dangerous Substances Annex ZA3</b>	Pass: the materials in the device do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations	<b>EN1155:1997+A1:2002/AC:2006</b>

Notified Body No. 2812

## Certificate of Constancy of Performance

2812-CPR-AE10495

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product:

### Allegion Briton 2720BD.T.EHO & 2721BD.T.EHO / Boss Door Controls TS6.SA-EMF & CISA 107209110 Surface Mounted Electrically Powered Hold Open Door Closer (Size 3 to 5)

Intended use: For use on fire single leaf and double leaf doors  
DOOR MOUNT PULL AND DOOR MOUNT PUSH SIDE APPLICATIONS

Essential Characteristics	Performance	Harmonised Technical Specification
<b>Ability to release</b> 5.1.2 release from any angle 5.1.3 Not possible to inhibit the release 5.1.4 Supply voltage 5.1.5 External electrical connection 5.1.6 Inlet for external wiring  5.2.1 General 5.2.2 Electrical release requirements 5.2.3 Door closing device requirements (EN1154)  5.2.4 Durability 5.2.5 Angle of hold open 5.2.6 Manual release 5.2.7 Continuous hold open 5.2.8 Overload performance 5.2.9 Delayed release 5.2.10 Electrical performance 5.2.11 Temperature Rise 5.2.12 Damage 5.2.13 Fire / smoke doors	Pass Pass 24v Pass Pass  Pass Pass Pass  Pass >65° Pass Pass Pass NPD Pass Pass Pass Grade 1	<b>EN1155:1997+A1:2002/AC:2006</b>
<b>Essential Characteristics</b>	<b>Performance</b>	<b>Harmonised Technical Specification</b>
<b>Durability of Ability to release</b>		
5.2.4 Durability	50,000 Test Cycles	
5.2.14.1 corrosion	Grade 3 (96 Hours)	
5.2.14.2 corrosion	Pass	
<b>Dangerous Substances Annex ZA3</b>	Pass: the materials in the device do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations	<b>EN1155:1997+A1:2002/AC:2006</b>

Notified Body No. 2812

## Certificate of Constancy of Performance

**2812-CPR-AE10495**

Placed on the Market under the Name of:

**ALLEGION UK LTD  
35 ROCKY LANE  
ASTON  
BIRMINGHAM  
B6 5RQ  
UNITED KINGDOM**

and produced in the manufacturing plants:

**E014110-1 & E014110-20**

**This is coded format, and the information is held by the Notified Body.**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

**EN 1155:1997+A1:2002/AC:2006**

Under System 1 for the performance set out in this certificate are applied and that the Factory Production Control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **23/10/2025** and will remain valid as long as neither the harmonised standard, the Construction Product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Notified Product Certification Body.

Valid to: **22/10/2028**

ERO Project Reference: **ERO 034621 P2832**



**Pascal Coget  
General Manager-European Certificate**

CSF408-NL 8.0