

Certificate of Constancy of Performance 2812-CPR-AE5012

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

Briton 3934 & BOSS TS7.004 Electrically Powered Hold Open & Freeswing Door Closer (Size 3 to 4)

Intended use: For use on fire single leaf and double leaf doors

STANDARD DOOR MOUNT PULL SIDE APPLICATION				
Essential Characteristics	Performance	Harmonised Technical Specification		
Mechanical Test Evidence: 141	262 / 141262/F / 141262/FP / 141262/P /	/ WIL 327386 / WIL 506536 /		
WIL 521855 & WIL 554162				
Fire Test Evidence: WF 138941 Iss 5 / WF 313740				
Ability to release				
5.1.2 release from any angle	Pass			
5.1.3 Not possible to inhibit the release				
5.1.4 Supply voltage	24V			
5.1.5 External electrical connection	Pass			
5.1.6 Inlet for external wiring	Pass			
5.2.1 General	Pass			
5.2.2 Electrical release requirements	Pass			
5.2.3 Door closing device requirements	Pass			
	_	EN1155:1997+A1:2002/AC:2006		
5.2.4 Durability	Pass			
5.2.5 Angle of hold open	Pass > 65°	J J		
5.2.6 Manual release	Pass			
5.2.7 Continuous hold open	Pass			
5.2.8 Overload performance	NPD			
5.2.9 Delayed release	NPD			
5.2.10 Electrical performance	Pass			
5.2.11 Temperature Rise	Pass			
5.2.12 Damage	Pass Crade 1			
5.2.13 Fire / smoke doors	Grade 1			
Durability of Ability to release 5.2.4 Durability	50,000 Test Cycles			
5.2.14.1 corrosion	Grade 3 (96 hours)			
5.2.14.1 corrosion 5.2.14.2 corrosion	Pass	1		
Dangerous Substances	Pass: the materials in the device do	EN1155:1997+A1:2002/AC:2006		
Annex ZA3	not contain or release any dangerous			
AIIIEX ZAS	substances in excess of the maximum			
	levels specified in existing European			
	material standards or any national			
	regulations			
	I Eguiations			



Certificate of Constancy of Performance 2812-CPR-AE5012

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

Briton 3934 & BOSS TS7.004 Electrically Powered Hold Open & Freeswing Door Closer (Size 4)

Intended use: For use on fire single leaf and double leaf doors

TRANSOM MOUNT PUSH SIDE APPLICATION				
Essential Characteristics	Performance	Harmonised Technical		
		Specification		
Ability to release				
5.1.2 release from any angle	Pass			
5.1.3 Not possible to inhibit the release	Pass			
5.1.4 Supply voltage	24V			
5.1.5 External electrical connection	Pass			
5.1.6 Inlet for external wiring	Pass			
		\		
5.2.1 General	Pass	\		
5.2.2 Electrical release requirements	Pass			
5.2.3 Door closing device requirements	Pass			
	_	EN1155:1997+A1:2002/AC:2006		
5.2.4 Durability	Pass			
5.2.5 Angle of hold open	Pass > 65°			
5.2.6 Manual release	Pass			
5.2.7 Continuous hold open	Pass			
5.2.8 Overload performance	NPD			
5.2.9 Delayed release	NPD			
5.2.10 Electrical performance	Pass			
5.2.11 Temperature Rise	Pass			
5.2.12 Damage 5.2.13 Fire / smoke doors	Pass Grade 1			
Durability of Ability to release	Grade			
5.2.4 Durability	50,000 Test Cycles			
5.2.4 Durability 5.2.14.1 corrosion	Grade 3 (96 hours)			
5.2.14.1 corrosion 5.2.14.2 corrosion	Pass			
Dangerous Substances	Pass: the materials in the device do	EN1155:1997+A1:2002/AC:2006		
Annex ZA3	not contain or release any dangerous			
AIIIGA ZAO	substances in excess of the maximum			
	levels specified in existing European			
	material standards or any national			
	regulations			
	1 - 3 - 3 - 3 - 3 - 3 - 3 - 3 - 3 - 3 -			





Certificate of Constancy of Performance 2812-CPR-AE5012

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

Briton 3934 & BOSS TS7.004 Electrically Powered Hold Open & Freeswing Door Closer (Size 3)

Intended use: For use on fire single leaf and double leaf doors
PARALLEL ARM APPLICATION

Essential Characteristics	PARALLEL ARM APPLICATION Performance	Harmonised Technical
	1 0110111181100	Specification
Ability to release		
5.1.2 release from any angle	Pass	
5.1.3 Not possible to inhibit the release	Pass	
5.1.4 Supply voltage	24V	
5.1.5 External electrical connection	Pass	
5.1.6 Inlet for external wiring	Pass	
/	_	\
5.2.1 General	Pass	
5.2.2 Electrical release requirements	Pass	
5.2.3 Door closing device requirements	Pass	EN4455 4007 : 44 0000/4 0 0000
E 2 4 Dumahilih	Dage	EN1155:1997+A1:2002/AC:2006
5.2.4 Durability	Pass Pass > 65°	
5.2.5 Angle of hold open 5.2.6 Manual release	Pass	
5.2.7 Continuous hold open	Pass	
5.2.8 Overload performance	NPD	
5.2.9 Delayed release	NPD	
5.2.10 Electrical performance	Pass	
5.2.11 Temperature Rise	Pass	
5.2.12 Damage	Pass	
5.2.13 Fire / smoke doors	Grade 1	
Durability of Ability to release		
5.2.4 Durability	50,000 Test Cycles	
5.2.14.1 corrosion	Grade 3 (96 hours)	
5.2.14.2 corrosion	Pass	
Dangerous Substances	Pass: the materials in the device do	EN1155:1997+A1:2002/AC:2006
Annex ZA3	not contain or release any dangerous	
	substances in excess of the maximum	
	levels specified in existing European	
	material standards or any national	
	regulations	



Certificate of Constancy of Performance 2812-CPR-AE5012

Placed on the Market under the Name of:

Allegion (UK) Limited
35 Rocky Lane
Aston
Birmingham
B6 5RQ
United Kingdom

and produced in the manufacturing plant:

E014110-22

This is coded format, and the information is held by the Notified Body.

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 1155:1997+A1:2002/AC:2006

Under System 1 for the performance set out in this certificate are applied and that the Factory Production Control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **30/10/2020** and reissued on **22/10/2025** and will remain valid as long as neither the designated standard, the Construction Product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Notified Product Certification Body.

CE Marking certificate valid to: 21/10/2028

ERO Project Reference: ERO 034621 P2981

Pascal Coget
General Manager European Certification



<u>_</u>#

