

Notified Body No. 2812

## Certificate of Constancy of Performance

### 2812-CPR-AF5003

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

## Briton 6100 999.XXX / Bricard 6100 999X / Cisa 1.07155.61.0.XX Door Coordinators (Size 3 to 5)

Intended use:- For use on fire rated double leaf doors.

Essential Characteristics	Performance	Harmonised Technical Specification
<b>Mechanical Test Ref's : WIL 355825</b>		
<b>Fire Test Ref's : WF No 358184 Iss 3 &amp; WF 391041 Iss 2</b>		
Self closing		<b>EN 1158:1997/A1:2002/AC:2006</b>
5.1 Product Information and design	Pass	
5.2.1 General	Pass	
5.2.2 Overload performance	Pass	
5.2.3 Manipulation performance	Pass	
5.2.4 Resistance of Waiting	Pass	
5.2.6 Damage	Pass	
5.2.8 Fire/smoke door suitability	Pass	
Essential Characteristics	Performance	Harmonised Technical Specification
Durability of Self Closing	(Grade 5)	<b>EN 1158:1997/A1:2002/AC:2006</b>
5.2.5 Durability	500,000 test cycles	
5.2.7.1 corrosion	(Grade 3) Pass	
5.2.7.2 corrosion	(Grade 3) Pass	
Dangerous Substances Annex ZA3	Pass: the materials in the door coordinator do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations	

Notified Body No. 2812

## Certificate of Constancy of Performance

### 2812-CPR-AF5003

Placed on the Market under the Name of:

**Allegion (UK) Ltd  
35 Rocky Lane  
Aston  
Birmingham  
B6 5RQ  
United Kingdom**

and produced in the manufacturing plant:

**E014110-1**

**This is coded format and the information is held by the Notified Body.**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

**EN 1158:1997/A1:2002/AC:2006**

Under System 1 for the performance set out in this certificate are applied and that the Factory Production Control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **30/10/2020** and reissued on **12/03/2026** and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Notified Product Certification Body.

CE Marking certificate valid to: **23/04/2026**

ERO Project Reference: **ERO 034621 P1943**



**Pascal Coget  
European Certification –General Manager**

CSF408-NL 8.0