**Notified Body No. 2812**

# Certificate of Constancy of Performance

# 2812-CPR-AD0168

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

# Briton 2003V Overhead Door Closer

**Intended use: For use on fire single leaf and double leaf doors**
**STANDARD DOOR MOUNT PULL SIDE APPLICATION**

| Essential characteristics | Performance | Designated Standard |
|---|---|---|
| **Mechanical Test Ref's :** WIL 507803<br>**Fire Test Ref's :** WF 501984/R & WF 502090 | | |
| Self closing<br>5.2.1 General | | **EN1154:1996/A1:2002/AC:2006** |
| 5.2.2 Durability | 500,000 test cycles | |
| 5.2.3 Closing moment | Pass size 2 to 4 | |
| 5.2.4 Opening moment | Pass size 2 to 4 | |
| 5.2.5 Efficiency | >50% size 2 | |
| 5.2.5 Efficiency | >60% size 4 | |
| 5.2.6 Closing time | Pass | |
| 5.2.7 Angles of operation | Grade 4, 180° | |
| 5.2.8 Overload performance | Pass | |
| 5.2.9 Temperature dependence | -15°C to +40°C | |
| 5.2.10 Fluid leakage | Pass | |
| 5.2.11 Damage | Pass | |
| 5.2.12 Latch control | Pass | |
| 5.2.13 Back check (optional) | Pass | |
| 5.2.14 Delayed closing (optional) | NPD | |
| 5.2.15 Adjustable closing force (optional) | Pass | |
| 5.2.16 Zero position (double action door closers only) | NPD | |
| 5.2.18 Fire/smoke door suitability | Pass | |
| **Essential characteristics** | **Performance** | **Designated Standard** |
| Durability of Self Closing<br>5.2.2 Durability | 500,000 test cycles | **EN1154:1996/A1:2002/AC:2006** |
| 5.2.17.1 corrosion | Grade 3 (96 hours) | |
| 5.2.17.2 corrosion | Pass | |
| Dangerous Substances<br>Annex ZA3 | Pass: the materials in the door closer do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations | |

**Notified Body No. 2812**

# Certificate of Constancy of Performance

# 2812-CPR-AD0168

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

# Briton 2003V Overhead Door Closer

**Intended use: For use on fire single leaf and double leaf doors**
**TRANSOM MOUNT PUSH SIDE APPLICATION**

| Essential characteristics | Performance | Designated Standard |
|---|---|---|
| Self closing<br>5.2.1 General | | EN1154:1996/A1:2002/AC:2006 |
| 5.2.2 Durability | 500,000 test cycles | |
| 5.2.3 Closing moment | Pass size 2 to 4 | |
| 5.2.4 Opening moment | Pass size 2 to 4 | |
| 5.2.5 Efficiency | >50% size 2 | |
| 5.2.5 Efficiency | >60% size 4 | |
| 5.2.6 Closing time | Pass | |
| 5.2.7 Angles of operation | Grade 3, 105° | |
| 5.2.8 Overload performance | Pass | |
| 5.2.9 Temperature dependence | -15°C to +40°C | |
| 5.2.10 Fluid leakage | Pass | |
| 5.2.11 Damage | Pass | |
| 5.2.12 Latch control | Pass | |
| 5.2.13 Back check (optional) | Pass | |
| 5.2.14 Delayed closing (optional) | NPD | |
| 5.2.15 Adjustable closing force (optional) | Pass | |
| 5.2.16 Zero position (double action door closers only) | NPD | |
| 5.2.18 Fire/smoke door suitability | Pass | |
| **Essential characteristics** | **Performance** | **Designated Standard** |
| Durability of Self Closing<br>5.2.2 Durability | 500,000 test cycles | EN1154:1996/A1:2002/AC:2006 |
| 5.2.17.1 corrosion | Grade 3 (96 hours) | |
| 5.2.17.2 corrosion | Pass | |
| Dangerous Substances<br>Annex ZA3 | Pass: the materials in the door closer do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations | |

**Notified Body No. 2812**

# Certificate of Constancy of Performance

# 2812-CPR-AD0168

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

# Briton 2003V Overhead Door Closer

**Intended use: For use on fire single leaf and double leaf doors**
**PARALLEL ARM APPLICATION**

| Essential characteristics | Performance | Designated Standard |
|---|---|---|
| Self closing<br>5.2.1 General | | EN1154:1996/A1:2002/AC:2006 |
| 5.2.2 Durability | 500,000 test cycles | |
| 5.2.3 Closing moment | Pass size 1 to 3 | |
| 5.2.4 Opening moment | Pass size 1 to 3 | |
| 5.2.5 Efficiency | >50% size 1 | |
| 5.2.5 Efficiency | >55% size 3 | |
| 5.2.6 Closing time | Pass | |
| 5.2.7 Angles of operation | Grade 3, 105° | |
| 5.2.8 Overload performance | Pass | |
| 5.2.9 Temperature dependence | -15°C to +40°C | |
| 5.2.10 Fluid leakage | Pass | |
| 5.2.11 Damage | Pass | |
| 5.2.12 Latch control | Pass | |
| 5.2.13 Back check (optional) | Pass | |
| 5.2.14 Delayed closing (optional) | NPD | |
| 5.2.15 Adjustable closing force (optional) | Pass | |
| 5.2.16 Zero position (double action door closers only) | NPD | |
| 5.2.18 Fire/smoke door suitability | Pass | |
| **Essential characteristics** | **Performance** | **Designated Standard** |
| Durability of Self Closing<br>5.2.2 Durability | 500,000 test cycles | EN1154:1996/A1:2002/AC:2006 |
| 5.2.17.1 corrosion | Grade 3 (96 hours) | |
| 5.2.17.2 corrosion | Pass | |
| Dangerous Substances<br>Annex ZA3 | Pass: the materials in the door closer do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations | |

**Notified Body No. 2812**

# Certificate of Constancy of Performance

## 2812-CPR-AD0168

**Placed on the market under the name of**

**Allegion Safety & Security Solutions Limited**
**Orbital 60**
**Dumers Lane**
**Bury**
**BL9 9UE**
**United Kingdom**

**and produced in the manufacturing plant:**

**E018761-9**

**This is coded format, and the information is held by the Notified Body.**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

## EN 1154:1996/A1:2002/AC:2006

Under System 1 for the performance set out in this certificate are applied and that the Factory production Control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **28/10/2020** and revised on **18/06/2026** and will remain valid as long as neither the harmonised standard, the Construction Product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Notified Product Certification Body.

CE Marking certificate valid to: **28/03/2029**

ERO Project Reference: **ERO 034621 P3355**

**Paul Duggan**
**Certification Manager**

CSF408-NL 8.0