Notified Body No. 2812

Certificate of Constancy of Performance

2812-CPR-AE0009

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product:

Briton 503 Electrically Powered Hold Open & Wall Magnet (Size 3 to 6)

Intended use: For use on fire single leaf and double leaf doors

Essential Characteristics	Performance	Harmonised Technical Specification
Mechanical Test Evidence: 108 PCT & 143578 **Fire Test Evidence:** WF 142517 Iss 2 & WF 145313 Iss 3		
Ability to release 5.1.2 release from any angle 5.1.3 Not possible to inhibit the release 5.1.4 Supply voltage 5.1.5 External electrical connection 5.1.6 Inlet for external wiring 5.2.1 General 5.2.2 Electrical release requirements 5.2.3 Door closing device requirements 5.2.4 Durability 5.2.5 Angle of hold open 5.2.6 Manual release 5.2.7 Continuous hold open 5.2.8 Overload performance 5.2.9 Delayed release 5.2.10 Electrical performance 5.2.11 Temperature Rise 5.2.12 Damage 5.2.13 Fire / smoke doors	 Pass Pass 24V Pass Pass Pass Pass NPD Pass Pass > 65° Pass Pass Pass NPD Pass Pass Pass Grade 1	**EN1155:1997+A1:2002/AC:2006**
Durability of Ability to release 5.2.4 Durability	 50,000 Test Cycles	**EN1155:1997+A1:2002/AC:2006**
5.2.14.1 corrosion	Grade 3 (96 hours)	
5.2.14.2 corrosion	Pass	
Dangerous Substances Annex ZA3	Pass: the materials in the device do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations	

Notified Body No. 2812

Certificate of Constancy of Performance

2812-CPR-AE0009

Placed on the market under the name of:

Allegion Safety & Security Solutions Limited
Orbital 60
Dumers Lane
Bury
BL9 9UE
United Kingdom

and produced in the manufacturing plant:

E018761-13

This is coded format and the information is held by the Notified Body.

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 1155:1997+A1:2002/AC:2006

Under System 1 for the performance set out in this certificate are applied and that the Factory Production Control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **29/10/2020** and revised on **18/06/2026** and will remain valid as long as neither the designated standard, the Construction Product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Notified Product Certification Body.

CE Marking certificate valid to: **03/04/2029**

ERO Project Reference: **ERO 034621 P3355**

Paul Duggan
Certification Manager

CSF408-NL 8.0