**Notified Body No. 2812**

# Certificate of Constancy of Performance

## 2812-CPR-AE0010

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product:

## Briton 533 Electrically Powered Hold Open & Wall Magnet (Size 3 to 6)

**Intended use: For use on fire single leaf and double leaf doors**

| Essential Characteristics | Performance | Harmonised Technical Specification |
|---|---|---|
| **Mechanical Test Evidence:** 108 PCT / 142577 & 157734<br>**Fire Test Evidence:** WF 142517 Iss 2 & WF 145313 Iss 3 | | |
| Ability to release<br>5.1.2 release from any angle<br>5.1.3 Not possible to inhibit the release<br>5.1.4 Supply voltage<br>5.1.5 External electrical connection<br>5.1.6 Inlet for external wiring<br><br>5.2.1 General<br>5.2.2 Electrical release requirements<br>5.2.3 Door closing device requirements<br><br>5.2.4 Durability<br>5.2.5 Angle of hold open<br>5.2.6 Manual release<br>5.2.7 Continuous hold open<br>5.2.8 Overload performance<br>5.2.9 Delayed release<br>5.2.10 Electrical performance<br>5.2.11 Temperature Rise<br>5.2.12 Damage<br>5.2.13 Fire / smoke doors | <br>Pass<br>Pass<br>24V<br>Pass<br>Pass<br><br>Pass<br>Pass<br>NPD<br><br>Pass<br>Pass > 65°<br>Pass<br>Pass<br>Pass<br>NPD<br>Pass<br>Pass<br>Pass<br>Grade 1 | **EN1155:1997+A1:2002/AC:2006** |
| Durability of Ability to release<br>5.2.4 Durability | <br>50,000 Test Cycles | **EN1155:1997+A1:2002/AC:2006** |
| 5.2.14.1 corrosion | Grade 3 (96 hours) | |
| 5.2.14.2 corrosion | Pass | |
| Dangerous Substances<br>Annex ZA3 | Pass: the materials in the device do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations | |

**Notified Body No. 2812**

# Certificate of Constancy of Performance

## 2812-CPR-AE0010

**Placed on the market under the name of:**

**Allegion Safety & Security Solutions Limited**
**Orbital 60**
**Dumers Lane**
**Bury**
**BL9 9UE**
**United Kingdom**

**and produced in the manufacturing plant:**

**E018761-13**

**This is coded format and the information is held by the Notified Body.**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

## EN 1155:1997+A1:2002/AC:2006

Under System 1 for the performance set out in this certificate are applied and that the Factory Production Control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **29/10/2020** and revised on **18/06/2026** and will remain valid as long as neither the designated standard, the Construction Product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Notified Product Certification Body.

CE Marking certificate valid to: **03/04/2029**

ERO Project Reference: **ERO 034621 P3355**

**Paul Duggan**
**Certification Manager**

CSF408-NL 8.0