

Notified Body No. 2812

Certificate of Constancy of Performance

2812-CPR-AG0017

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product:

Briton 5400 Series Mortice Dead Locks **See Annex A**

Intended use: For use on fire/smoke compartmentation doors

Essential characteristics	Performance	Harmonised technical specification
Mechanical test evidence: WIL 414122 & WIL 414785 Fire test evidence: WF 413358 iss.2, WF 417357 & WF 422917 iss.4		
Self-closing ability 5.4.2 Closing force	NPD	EN 12209:2003 / AC:2005
5.1.2 Return force of latch bolt	NPD	
Durability of self-closing action 5.3.1 Durability of latch action	NPD	
Ability to maintain the door in the closed position and not contribute to its spread of fire 5.2.1 Resistance to side load on latch bolt	NPD	
5.5 Suitability for use on fire/smoke doors	Grade 1: suitable for use on fire/smoke resistant door assemblies	
Control of dangerous substances 5.1.1 Dangerous substances	Pass: The materials in the lock do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations (1)	

Notified Body No. 2812

Certificate of Constancy of Performance

2812-CPR-AG0017

Placed on the Market under the Name of:

**Allegion (UK) Ltd
35 Rocky Lane
Aston
Birmingham
B6 5RQ
United Kingdom**

and produced in the manufacturing plant:

E014110-13

This is coded format, and the information is held by the Notified Body.

This certificate attests that all provisions concerning the Assessment and Verification of Constancy of Performance described in Annex ZA of the standard(s):

EN 12209:2003 / AC:2005

Under System 1 for the performance set out in this certificate are applied and that the Factory Production Control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **30/10/2020** and reissued on **24/11/2025** and will remain valid as long as neither the harmonised standard, the Construction Product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Notified Product Certification Body.

Valid to: **19/12/2028**

ERO Project Reference: **ERO 034621 P2918**



**Pascal Coget
General Manager – European Certification**

CSF408-NL 8.0

Notified Body No. 2812

Certificate of Constancy of Performance

2812-CPR-AG0017

Annex A

Model No.	Description	Backset
Briton 5410.55.S Briton 5410.55.R	Euro profile cylinder mortice deadlock Square or radiused forend	55mm
Briton 5410.60.S Briton 5410.60.R	Euro profile cylinder mortice deadlock Square or radiused forend	60mm

SS

Forends available in the following finishes:
Satin stainless steel

