

## Declaration of Performance

### CONSTRUCTION PRODUCTS REGULATION 2011 DECLARATION OF PERFORMANCE

**No. AL-0000401614**

1. Unique identification code of the product-type:

**Briton 1120B Overhead Door Closer**

2. Type, batch or serial number or any other element allowing identification of the construction product as required under Article 11(4) of the CPR:

**Briton 1120B**

3. Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:

**For use on fire and smoke compartmentation doors (to fulfil the self-closing requirements of such doors).**

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required under Article 11(5):

**Allegion (UK) Limited  
35 Rocky Lane  
Aston  
Birmingham  
B6 5RQ**

5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):

**N/A**

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in CPR, Annex V:

**System 1**

7. In case of the declaration of performance concerning a construction product covered by a harmonized standard:

**EN 1154: 1996: A1: 2002/AC:2006  
Notified Certification body No.2812 performed the type testing and issued test reports.  
Certificate of Constancy of Performance - 2812-CPR- AD0034**

8. European Technical Assessment:

**N/A**

9. Declared performance

Essential characteristics	Performance	Harmonised technical specification
<b>Self closing</b> <b>5.2.1 General</b>  <b>Application</b>  <b>5.2.2 Durability</b> <b>5.2.3 Closing moment</b> <b>5.2.4 Opening moment</b>	<b>Door Mount Pull Side (Fig 1) &amp; Transom Mount Push Side (Fig 61)</b>  <b>500,000</b> <b>Pass size 2-4</b> <b>Pass size 2-4</b>	<b>EN 1154: 1996: A1: 2002/AC:2006</b>

<b>5.2.5 Efficiency</b>  <b>5.2.6 Closing time</b> <b>5.2.7 Angles of operation</b> <b>5.2.8 Overload performance</b> <b>5.2.9 Temperature dependence</b> <b>5.2.10 Fluid leakage</b> <b>5.2.11 Damage</b> <b>5.2.12 Latch control</b> <b>5.2.13 Backcheck</b> <b>5.2.14 Delayed Action</b> <b>5.2.15 Adjustable closing force</b> <b>5.2.16 Zero position (double action doors only)</b> <b>5.2.18 Fire / smoke doors</b>	<b>&gt;50% size 2</b> <b>&gt;60% size 4</b>  <b>Pass</b> <b>Grade 4, 180°</b> <b>Pass</b> <b>-15°C to +40°C</b> <b>Pass</b> <b>Pass</b> <b>Pass</b> <b>Pass</b> <b>NPD</b> <b>Pass</b> <b>NPD</b>  <b>Grade 1: suitable for use on fire/smoke doors (≥EN3 )</b>	
<b>Essential characteristics</b>	<b>Performance</b>	<b>Harmonised technical specification</b>
<u><b>Durability of Self Closing</b></u> <b>5.2.2 Durability</b> <b>5.2.17.1 corrosion</b> <b>5.2.17.2 corrosion</b>  <u><b>Dangerous Substances</b></u> <u><b>Annex ZA3</b></u>	<b>500,000</b> <b>Grade 3 (96 hours)</b> <b>Pass</b>   <b>Pass</b>	<b>EN 1154: 1996: A1: 2002/AC:2006</b>

10. The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

Peter Hancox  
UK General Manager



Allegion (UK) Limited  
35 Rocky Lane  
Aston  
Birmingham  
B6 5RQ

19th May 2025

## Declaration of Performance

### CONSTRUCTION PRODUCTS REGULATION 2011 DECLARATION OF PERFORMANCE

**No. AL-0000401614**

1. Unique identification code of the product-type:

**Briton 1120B Overhead Door Closer**

2. Type, batch or serial number or any other element allowing identification of the construction product as required under Article 11(4) of the CPR:

**Briton 1120B**

3. Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:

**For use on fire and smoke compartmentation doors (to fulfil the self-closing requirements of such doors).**

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required under Article 11(5):

**Allegion  
Bescot Crescent  
Walsall  
WS1 4DL**

5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):

**N/A**

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in CPR, Annex V:

**System 1**

7. In case of the declaration of performance concerning a construction product covered by a harmonized standard:

**EN 1154: 1996: A1: 2002/AC:2006  
Notified Certification body No.2812 performed the type testing and issued test reports.  
Certificate of Constancy of Performance - 2812-CPR- AD0034**

8. European Technical Assessment:

**N/A**

9. Declared performance

Essential characteristics	Performance	Harmonised technical specification
<b>Self closing</b> <b>5.2.1 General</b>  <b>Application</b>  <b>5.2.2 Durability</b> <b>5.2.3 Closing moment</b> <b>5.2.4 Opening moment</b> <b>5.2.5 Efficiency</b>	<b>Parallel Arm (Fig 66)</b>   <b>500,000</b> <b>Pass size 3-4</b> <b>Pass size 3-4</b> <b>&gt;55% size 3</b> <b>&gt;60% size 4</b>	<b>EN 1154: 1996: A1: 2002/AC:2006</b>

5.2.6 Closing time 5.2.7 Angles of operation 5.2.8 Overload performance 5.2.9 Temperature dependence 5.2.10 Fluid leakage 5.2.11 Damage 5.2.12 Latch control 5.2.13 Backcheck 5.2.14 Delayed Action 5.2.15 Adjustable closing force 5.2.16 Zero position (double action doors only) 5.2.18 Fire / smoke doors	Pass Grade 3, >105° Pass -15°C to +40°C Pass Pass NPD Pass NPD Pass NPD Grade 1: suitable for use on fire/smoke doors (≥EN3 )	
Essential characteristics	Performance	Harmonised technical specification
<u>Durability of Self Closing</u> 5.2.2 Durability 5.2.17.1 corrosion 5.2.17.2 corrosion	500,000 Grade 3 (96 hours) Pass	EN 1154: 1996: A1: 2002/AC:2006
<u>Dangerous Substances</u> <u>Annex ZA3</u>	Pass	

10. The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

Peter Hancox  
UK General Manager

Perlettengo

Allegion (UK) Limited  
35 Rocky Lane  
Aston  
Birmingham  
B6 5RQ

19th May 2025