Declaration of Performance

CONSTRUCTION PRODUCTS REGULATION 2011
DECLARATION OF PERFORMANCE

No. AL-0000401631

1. Unique identification code of the product-type:

Briton 2320B.T, 2320B.T.S & Briton 2321B.T, 2312B.T.S Overhead Door Closers

2 Type, batch or serial number or any other element allowing identification of the construction product as required under Article 11(4) of the CPR:

Briton 2320B.T, 2320B.T.S & Briton 2321B.T, 2312B.T.S Overhead Door Closers

3. Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:

For use on fire and smoke compartmentation doors (to fulfil the self-closing requirements of such doors).

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required under Article 11(5):

Allegion Safety & Security Solutions Limited
Orbital 60
Dumers Lane
Bury
BL9 9UE

5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):

N/A

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in CPR, Annex V:

System 1

7. In case of the declaration of performance concerning a construction product covered by a harmonized standard:

EN 1154: 1996: A1: 2002/AC:2006
Notified Certification body No.2812 performed the type testing and issued test reports.
Certificate of Constancy of Performance - 2812-CPR- AD5118

8. European Technical Assessment:

N/A

9. Declared performance

Essential characteristics	Performance	Harmonised technical specification
Self closing		
5.2.1 General		
Application	**Door Mount Pull (2320)** **Transom Mount Pull (2321)**	**EN 1154: 1996: A1: 2002/AC:2006**
5.2.2 Durability	**500,000**	
5.2.3 Closing moment	**Pass size 2-4**	
5.2.4 Opening moment	**Pass size 2-4**	

5.2.5 Efficiency **5.2.6 Closing time** **5.2.7 Angles of operation** **5.2.8 Overload performance** **5.2.9 Temperature dependence** **5.2.10 Fluid leakage** **5.2.11 Damage** **5.2.12 Latch control** **5.2.13 Backcheck** **5.2.14 Delayed Action** **5.2.15 Adjustable closing force** **5.2.16 Zero position (double action doors only)** **5.2.18 Fire / smoke doors**	**>50% size 2** **>60% size 4** **Pass** **Grade 4, 180°** **Pass** **-15°C to +40°C** **Pass** **Pass** **Pass** **Pass** **NPD** **Pass** **NPD** **Pass**	
Essential characteristics	**Performance**	**Harmonised technical specification**
Durability of Self Closing **5.2.2 Durability** **5.2.17.1 corrosion** **5.2.17.2 corrosion** **Dangerous Substances** **Annex ZA3**	 **500,000** **Grade 3 (96 hours)** **Pass** **Pass**	**EN 1154: 1996: A1: 2002/AC:2006**

10. The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:



Peter Hancox
UK General Manager

1st of June 2026

Allegion Safety & Security Solutions Limited
Orbital 60
Dumers Lane
Bury
BL9 9UE

Declaration of performance

CONSTRUCTION PRODUCTS REGULATION 2011
DECLARATION OF PERFORMANCE

No. AL-0000401631

1. Unique identification code of the product-type:

Briton 2320B.T, 2320B.T.S & Briton 2321B.T, 2312B.T.S Overhead Door Closers

2 Type, batch or serial number or any other element allowing identification of the construction product as required under Article 11(4) of the CPR:

Briton 2320B.T, 2320B.T.S & Briton 2321B.T, 2312B.T.S Overhead Door Closers

3. Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:

For use on fire and smoke compartmentation doors (to fulfil the self-closing requirements of such doors).

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required under Article 11(5):

Allegion Safety & Security Solutions Limited
Orbital 60
Dumers Lane
Bury
BL9 9UE

5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):

N/A

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in CPR, Annex V:

System 1

7. In case of the declaration of performance concerning a construction product covered by a harmonized standard:

EN 1154: 1996: A1: 2002/AC:2006
Notified Certification body No.2812 performed the type testing and issued test reports.
Certificate of Constancy of Performance - 2812-CPR- AD5118

8. European Technical Assessment:

N/A

9. Declared performance

Essential characteristics	Performance	Harmonised technical specification
Self closing		
5.2.1 General		
Application	**Door Mount Push (2321)**	
5.2.2 Durability	**500,000**	**EN 1154: 1996: A1: 2002/AC:2006**
5.2.3 Closing moment	**Pass size 2-4**	
5.2.4 Opening moment	**Pass size 2-4**	
5.2.5 Efficiency	**>50% size 2** **>60% size 4**	

5.2.6 Closing time **5.2.7 Angles of operation** **5.2.8 Overload performance** **5.2.9 Temperature dependence** **5.2.10 Fluid leakage** **5.2.11 Damage** **5.2.12 Latch control** **5.2.13 Backcheck** **5.2.14 Delayed Action** **5.2.15 Adjustable closing force** **5.2.16 Zero position (double action doors only)** **5.2.18 Fire / smoke doors**	**Pass** **Grade 3, >105°** **Pass** **-15°C to +40°C** **Pass** **Pass** **Pass** **Pass** **NPD** **Pass** **NPD** **Pass**	
Essential characteristics	**Performance**	**Harmonised technical specification**
<u>Durability of Self Closing</u> **5.2.2 Durability** **5.2.17.1 corrosion** **5.2.17.2 corrosion** **<u>Dangerous Substances</u>** **<u>Annex ZA3</u>**	 **500,000** **Grade 3 (96 hours)** **Pass** **Pass**	 **EN 1154: 1996: A1: 2002/AC:2006**

10. The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:



Peter Hancox
UK General Manager

1st of June 2026

Allegion Safety & Security Solutions Limited
Orbital 60
Dumers Lane
Bury
BL9 9UE

Declaration of performance

CONSTRUCTION PRODUCTS REGULATION 2011
DECLARATION OF PERFORMANCE

No. AL-0000401631

2. Unique identification code of the product-type:

Briton 2320B.T, 2320B.T.S & Briton 2321B.T, 2312B.T.S Overhead Door Closers

2 Type, batch or serial number or any other element allowing identification of the construction product as required under Article 11(4) of the CPR:

Briton 2320B.T, 2320B.T.S & Briton 2321B.T, 2312B.T.S Overhead Door Closers

3. Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:

For use on fire and smoke compartmentation doors (to fulfil the self-closing requirements of such doors).

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required under Article 11(5):

Allegion Safety & Security Solutions Limited
Orbital 60
Dumers Lane
Bury
BL9 9UE

5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):

N/A

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in CPR, Annex V:

System 1

7. In case of the declaration of performance concerning a construction product covered by a harmonized standard:

EN 1154: 1996: A1: 2002/AC:2006
Notified Certification body No.2812 performed the type testing and issued test reports.
Certificate of Constancy of Performance - 2812-CPR- AD5118

8. European Technical Assessment:

N/A

9. Declared performance

Essential characteristics	Performance	Harmonised technical specification
Self closing		
5.2.1 General		
Application	**Transom Mount Push (2320)**	
5.2.2 Durability	**500,000**	**EN 1154: 1996: A1: 2002/AC:2006**
5.2.3 Closing moment	**Pass size 2-4**	
5.2.4 Opening moment	**Pass size 2-4**	
5.2.5 Efficiency	**>50% size 2** **>60% size 4**	
5.2.6 Closing time	**Pass**	
5.2.7 Angles of operation	**Grade 3, >105°**	
5.2.8 Overload performance	**Pass**	

5.2.9 Temperature dependence **5.2.10 Fluid leakage** **5.2.11 Damage** **5.2.12 Latch control** **5.2.13 Backcheck** **5.2.14 Delayed Action** **5.2.15 Adjustable closing force** **5.2.16 Zero position (double action doors only)** **5.2.18 Fire / smoke doors**	**-15°C to +40°C** **Pass** **Pass** **Pass** **Pass** **NPD** **Pass** **NPD** **Pass**	
Essential characteristics	**Performance**	**Harmonised technical specification**
<u>Durability of Self Closing</u> **5.2.2 Durability** **5.2.17.1 corrosion** **5.2.17.2 corrosion** **<u>Dangerous Substances Annex ZA3</u>**	 **500,000** **Grade 3 (96 hours)** **Pass** **Pass**	**EN 1154: 1996: A1: 2002/AC:2006**

10. The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:



Peter Hancox
UK General Manager

1st of June 2026

Allegion Safety & Security Solutions Limited
Orbital 60
Dumers Lane
Bury
BL9 9UE