Declaration of Performance

UK CONSTRUCTION PRODUCTS
(AMENDMENT ETC) (EU EXIT)
REGULATIONS 2020

No. 47430832

1. Unique identification code of the product-type:

Briton 2420.T Concealed Overhead Door Closers

2 Type, batch or serial number or any other element allowing identification of the construction product as required under Article 11(4) of the UK CPR:

Briton 2420.T Concealed Overhead Door Closers

3. Intended use or uses of the construction product, in accordance with the applicable designated technical specification, as foreseen by the manufacturer:

For use on fire and smoke compartmentation doors (to fulfil the self-closing requirements of such doors).

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required under Article 11(5):

Allegion Safety & Security Solutions Limited
Orbital 60
Dumers Lane
Bury
BL9 9UE

5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):

N/A

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in UK CPR, Annex V:

System 1

7. In case of the declaration of performance concerning a construction product covered by a designated standard:

EN 1154: 1996: A1: 2002/AC:2006
Approved Certification body No.1121 performed the type testing and issued test reports.
Certificate of Constancy of Performance - 1121-CPR-UK- AD7604

8. UK Technical Assessment:

N/A

9. Declared performance

Essential characteristics	Performance	Designated technical specification
Self closing **5.2.1 General** **Application**	 **Concealed in Door** **Concealed in Transom**	

		EN 1154: 1996: A1: 2002/AC:2006
5.2.2 Durability	500,000	
5.2.3 Closing moment	Pass size 2-4	
5.2.4 Opening moment	Pass size 2-4	
5.2.5 Efficiency	>50% size 2 >60% size 4	
5.2.6 Closing time	Pass	
5.2.7 Angles of operation	Grade 3, >105°	
5.2.8 Overload performance	Pass	
5.2.9 Temperature dependence	-15°C to +40°C	
5.2.10 Fluid leakage	Pass	
5.2.11 Damage	Pass	
5.2.12 Latch control	Pass	
5.2.13 Backcheck	NPD	
5.2.14 Delayed Action	NPD	
5.2.15 Adjustable closing force	Pass	
5.2.16 Zero position (double action doors only)	NPD	
5.2.18 Fire / smoke doors	Pass	
Essential characteristics	**Performance**	**Designated technical specification**
Durability of Self Closing		
5.2.2 Durability	500,000	
5.2.17.1 corrosion	Grade 3 (96 hours)	
5.2.17.2 corrosion	Pass	EN 1154: 1996: A1: 2002/AC:2006
Dangerous Substances Annex ZA3	Pass	

10. The performance of the product identified above is in conformity with the set of declared performance(s). This Declaration of Performance is issued, in accordance with Regulation (EU) No 305/2011 as it has effect in the United Kingdom in respect of Great Britain, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

Peter Hancox
UK General Manager

1st of June 2026

Allegion Safety & Security Solutions Limited
Orbital 60
Dumers Lane
Bury
BL9 9UE