

## Declaration of Performance

### UK CONSTRUCTION PRODUCTS (AMENDMENT ETC) (EU EXIT) REGULATIONS 2020

No. 47510399

1. Unique identification code of the product-type:

**Briton 6100 999 Double Door Coordinator (Size 3 to 5)**

2. Type, batch or serial number or any other element allowing identification of the construction product as required under Article 11(4) of the UK CPR:

**Briton 6100 999 Double Door Coordinator**

3. Intended use or uses of the construction product, in accordance with the applicable designated technical specification, as foreseen by the manufacturer:

**For use on fire and smoke compartmentation doors (to fulfil the self-closing requirements of such doors).**

4. Name, registered trade name or registered trademark and contact address of the manufacturer as required under Article 11(5):

**Allegion (UK) Limited  
35 Rocky Lane  
Aston  
Birmingham  
B6 5RQ**

5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):

**N/A**

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in UK CPR, Annex V:

**System 1**

7. In case of the declaration of performance concerning a construction product covered by a designated standard:

**EN 1158:1996/A1:2002/AC:2006  
Approved Certification body No.1121 performed the type testing and issued test reports.  
Certificate of Constancy of Performance - 1121-CPR-UK-AF7619**

8. UK Technical Assessment:

**N/A**

9. Declared performance

Essential characteristics	Performance	Designated technical specification
Self closing		
5.1 Product Information and design	Pass	
5.2.1 General	Pass	
5.2.2 Overload performance	Pass	
5.2.3 Manipulation performance	Pass	

5.2.4 Resistance of Waiting	Pass	EN 1158:1997/A1:2002/AC:2006
5.2.6 Damage	Pass	
5.2.8 Fire/smoke door suitability	Pass	
Essential characteristics	Performance	Designated technical specification
Durability of Self Closing 5.2.5 Durability	(Grade 5) 500,000 test cycles	EN 1158:1997/A1:2002/AC:2006
5.2.17.1 corrosion	Grade 3 (96 hours)	
5.2.17.2 corrosion	Pass	
Dangerous Substances Annex ZA3	<b>Pass:</b> the materials in the door coordinator do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations	

10. The performance of the product identified above is in conformity with the set of declared performance(s). This Declaration of Performance is issued, in accordance with Regulation (EU) No 305/2011 as it has effect in the United Kingdom in respect of Great Britain, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

Peter Hancox  
UK General Manager



Allegion (UK) Limited  
35 Rocky Lane  
Aston  
Birmingham  
B6 5RQ

21st May 2025